

**PUBLIC NOTICE
INVITATION TO BID**

THE CITY OF METTER IS ACCEPTING SEALED BIDS FOR 6" SOLIDS
HANDLING VACUUM-ASSISTED PORTABLE PUMP

**BIDS ARE DUE BY WEDNESDAY, OCTOBER 5, 2022, AT 2:00 P.M. AT
METTER PUBLIC WORKS, LOCATED AT 700 WASHINGTON STREET,
METTER, GA.**

A COPY OF THE BID SPECIFICATIONS CAN BE PICKED UP AT METTER CITY
HALL, LOCATED AT 49 SOUTH ROUNTREE STREET, METTER, GA. FROM
PURCHASING, MANAGER: MISSY EDENFIELD, MONDAY THROUGH FRIDAY
BETWEEN THE HOURS OF 8:00 A.M. TO 4:00 P.M.

FOR ALL INQUIRES CONCERNING THE BID SPECIFICATIONS CONTACT:
CLIFF HENDRIX AT METTER PUBLIC WORKS, LOCATED AT 700
WASHINGTON STREET, METTER, GEORGIA 30439 OR BY TELEPHONE AT
(912)-685-7845 OR BY EMAIL AT chendrix@cityofmetterga.gov.

**THE CITY OF METTER RESERVES THE RIGHT TO REJECT ANY AND ALL
BIDS.**

All bids are to be enclosed in a sealed envelope and address on the outside as follows:

**METTER PORTABLE PUMP
CITY OF METTER
49 SOUTH ROUNTREE STREET
P. O. BOX 74
METTER, GEORGIA 30439
ATTENTION: MISSY EDENFIELD, PURCHASING MANAGER**

**CITY OF METTER
P.O. BOX 74
METTER, GEORGIA 30439**

SPECIFICATIONS FOR A 6" SOLIDS HANDLING VACUUM-ASSISTED PORTABLE PUMP (Dry Prime)

1. Heavy duty class 30 cast-iron pump casing
2. Can produce flows up to 2,450 gpm
3. 6" Suction size
4. 6" Discharge size
5. 1 minimum 100-gallon diesel tank
6. Heads 120 ft
7. High quality stress-proof steel shaft
8. 50' of 6" suction hose
9. 50' of 6" discharge hose
10. Fuel tank 100 gallon
11. Tier 4 DOC (Diesel Oxidation Catalyst)-No DEF
12. Trailer to have hitch for 2" ball
13. Pump Casing ductile iron, tangential discharge
14. Impeller ductile iron
15. 40 HP @ 1800 rpm diesel engine or equivalent
16. Turbocharged, high pressure common-rail diesel with automatic shutdown
17. One 12 VDC style alarm notification system to notify city cell phone of problems
- 18. Identify any exceptions to the above specs and include those items**
- 19. The City of Metter reserves the right to reject any and all bids**
- 20. A parts and operations manual**
- 21. Please list any and all warrants**
- 22. Unit to be delivered to the Metter Public Works Department in the City of Metter at 700
Washington St.**