

PUBLIC NOTICE INVITATION TO BID

THE CITY OF METTER IS ACCEPTING SEALED BIDS FOR A NEW HVAC UNIT FOR THE POLICE DEPARTMENT.

BIDS ARE DUE BY WEDNESDAY, OCTOBER 4, 2023, AT 2:00 P.M. AT METTER CITY HALL, LOCATED AT 49 SOUTH ROUNTREE SREET, METTER, GA.

A COPY OF THE BID SPECIFICATIONS CAN BE PICKED UP AT METTER CITY HALL, LOCATED AT 49 SOUTH ROUNTREE STREET, METTER, GA. FROM PURCHASING MANAGER: MISSY EDENFIELD, MONDAY THROUGH FRIDAY BETWEEN THE HOURS OF 8:00 A.M. TO 4:00 P.M.

FOR ALL INQUIRES CONCERNING THE BID SPECIFICATIONS CONTACT: MISSY EDENFIELD AT METTER CITY HALL, LOCATED AT 49 SOUTH ROUNTREE STREET, METTER, GEORGIA 30439 OR BY TELEPHONE (912)-685-2527 OR BY EMAIL AT medenfield@cityofmetterga.gov.

THE CITY OF METTER RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS.

All bids are to be enclosed in a sealed envelope and address on the outside as follows:

**METTER POLICE DEPARTMENT HVAC UNIT
CITY OF METTER
49 SOUTH ROUNTREE STREET
P. O. BOX 74
METTER, GEORGIA 30439
ATTENTION: MISSY EDENFIELD, PURCHASING MANAGER**

**CITY OF METTER
P.O. BOX 74
METTER, GEORGIA 30439**

SPECIFICATIONS FOR 10 TON HVAC REPLACEMENT FOR POLICE DEPARTMENT

SCOPE OF WORK:

1. REMOVE EXISTING 10 TON SPLIT HEAT PUMP SYSTEM AND DISPOSE.
2. PROVIDE AND INSTALL A NEW 10 TON CARRIER 38AUQD120A5/40RFQA12A2A5 UNIT.
3. DEMO AND REPLACE REFRIGERANT LINES WITH 1 1/8" AND 1/2" HARD DRAWN COPPER. SUCTION LINE WILL BE INSULATED WITH 3/4" INSULATION AND MITERED AT ALL ELBOWS.
4. AIRHANDLER AND OUTDOOR CONDENSER WILL BE INSTALLED ON VIBRATION ISOLATION PADS.
5. MODIFY AND CONNECT TO EXISTING ELECTRICAL.
6. MODIFY AND RECONNECT TO EXISTING CONDENSATE DRAIN. CONDENSATE DRAIN WILL BE INSULATED WITH 1" INSULATION.
7. PROVIDE AND INSTALL HONEYWELL VISION PRO 8000.
8. TEST TO CONFIRM SMOKE DETECTOR OPERATION AND SHUT DOWN.
9. CERTIFIED TEST AND BALANCE IS NOT REQUIRED.
10. 5 YEARS PARTS AND LABOR WARRANTY.